

**Office of the Joint Director Fire & Emergency Services  
Jammu Range, Jammu**

**The Principal  
The Shri Ram Universal School  
15 Milestones NH-1, near Holy Water Pond  
Shri Vihar Jakh, Samba**

No: DJF&ES/FPI/4335

Dated: 5.10.2020

Sub: Fire Safety Certificate.

Ref: Your Letter dated: 07.07.2020.


**Sir,**

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed Hydrants and sufficient numbers of First Aid Fire Extinguishers in their school premises, besides two underground water storage tanks of 10 KL capacity each respectively. The school is about 15 Km away from Fire & Emergency Station Bari - Brahmana and is approachable for fire appliances in case of any emergency. Since the school is already functioning as such, the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures in letter and spirit forthwith:--

1. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
2. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building. The management shall intimate the office of Assistant Director, Fire & Emergency Services Command Samba - Kathua after each quarter that the fire fighting equipments installed in the school are functioning.
3. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
4. The corridor of the building shall not be used for any kind of storage.
5. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
6. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
7. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
8. At present school is triple storey. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
9. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
10. The validity of this clearance shall remain enforce for one year and same needs to be renewed after checking of fire fighting system installed in the school.

Yours Sincerely

  
**Joint Director  
Fire & Emergency Services  
Jammu Range, Jammu**

  
PRINCIPAL  
The Shri Ram Universal School  
Jakh, Jammu.

Rajni Gupta  
MANAGER  
The Shri Ram Universal School  
Jakh, Jammu.